

 Test-plan	Project:	PSL204/AMS12 Rev.B		Date:	20.06.06	PS Automation GmbH Gesellschaft für Antriebstechnik Philipp-Krämer-Ring 13 67098 Bad Dürkheim
	Project-no.:			Test phase finished:		
	Customer:			Revision date:	20.06.06	
	Test instruction:			Index:	B	
	Test phase:	Typenprüfung		Test planning from:	Gu, Jicheng	
				Released from:		

pos.	Test description	Test parameters	Acceptance requirements	Design level	Test institute	Qty.	Sample No.	Start date	Stop date	Specification fulfilled		Test report no. & remarks
										Yes	No	
15.2	Linear actuator design live	prEN WI 6900095 vom 2004-10	4.1.3 Class C 1.800.000 Anläufe min 1% Hub bei min 30% Kraft bei 25°C	A	PS EMV Labor	2	#0012 #0014	02.05	09.05	☒	☐	Betrieb auf Feder AMS11_PSL_Klimav ersuch.xls

PS AUTOMATION GmbH
 Philipp-Krämer-Ring 13
 67098 Bad Dürkheim
 Postfach 1662
 67090 Bad Dürkheim

Distribution list:	Released by customer:	Name: <u>Berthold</u>	Signature: 	Date: <u>15.06.13</u>
Copies:	Released by customer:	Name:	Signature:	Date: